

**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
LISTING SERVICE**

**LISTING No.**

7165-1574:149

Page 1 of 2

**CATEGORY:**

Control Unit (Non High-Rise)

**LISTEE:**

ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ 07004-1561  
Contact: Ron Dalton \*(310) 619-2342 FAX \*(310) 619-2208

**DESIGN:**

Models "Focus 100C" (7182-403, -503) and "Focus 100D" (472341,472342) fire alarm control units. Automatic, manual, local, remote station, central station, waterflow and sprinkler supervisory services. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

7182-403, -503, 472341, 472342	Control Units
7187-200	Keypad
7187-119	Printer Interface
7187-067	Watch-Dog Module
7187-220, 443218, 471805	Transformer Unit
7187-002	Alarm Transmitter
7187-003, -005	Communication Module
7187-202	Battery Enclosure
7187-027	Housing Unit
7137-006	Single Input PID Module
7137-007	Quad PID Module
7187-011	Retrofit PA PID Module
7137-012	Commendable Output PID
7187-02B	Quad Sounder PID
7187-039	Waterflow Retard PID
7187-084, -085	Derived local Channel
71 B7-014	Raucous Sounder
7187-099, 472318	Universal Communicator
7187-106, -206	Micro PID Module
7187-227	Micro PID Housing

**INSTALLATION:**

In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable for the authority having jurisdiction.

\*Rev. 06-03-05

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** Formerly 7165-0085:160

\*Rev. 06-03-05



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MARCH 15, 2006**

*Listing Expires **June 30, 2007***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager